Schaeffer's FUEL ADDITIVES
## SINCE 1839
Good people. Great products.

Winter Fuel Testing

## Indiana   December 2016

137 ULSW — West Terre Haute, IN

Cloud Point	No Additive	1:1000	1:750
5°	NaN°	3°	3°

Sample B — Chesterton, IN

Cloud Point	No Additive	1:3000
-15°	NaN°	-29°

Sample A — Chesterton, IN

Cloud Point	No Additive	1:3000
-15°	NaN°	-29°